

**Certificate Number:** AZ 69025357

Page: 0005



## CERTIFICATE OF SUITABILITY

Authorised marking: TUV025357E

CONTINUATION SHEET 4

(Modification 1)

1. Update standard from AS/NZS 4777.2:2020 to AS/NZS 4777.2: 2020 + A1;
2. Change DC switch to GHX5-32P, BEIJING PEOPLE'S ELECTRIC PLANT CO., LTD. AZ 69025800.
3. Change the PV short circuit current  $I_{sc}$  of RHI-3P5K-HVES-5G and RHI-3P6K-HVES-5G from 19.5+19.5A to 16.5+16.5A,
4. Change the PV short circuit current  $I_{sc}$  of RHI-3P8K-HVES-5G from 39A + 19.5A to 32.5A+16.5A,
5. Change the PV short circuit current  $I_{sc}$  of RHI-3P10K-HVES-5G from 39A + 39A to 32.5A+32.5A,

Issue Date: 28/04/2022

Expiry Date: 15/10/2026

*Signed for and on behalf of TÜV Rheinland Australia Pty Ltd*

A handwritten signature in blue ink, appearing to read 'Grant Li', positioned above a horizontal line.

Grant Li



Acc. No. Z2870404AA  
[www.jas-anz.org/register](http://www.jas-anz.org/register)